

Certyfikat zgodności WE

1396 — CPD — 0050

Zgodnie z wytycznymi Dyrektywy 89/106/EEC Rady Wspólnoty Europejskiej z dnia 21 grudnia 1988 w sprawie dostosowania przepisów prawnych i administracyjnych państw członkowskich dotyczących produktów budowlanych (CPD - wytyczne dotyczące produktów budowlanych) zmienione przez wytyczne Dyrektywy 93/68/EEC Rady Wspólnoty Europejskiej z dnia 22 lipca 1993, niniejszym poświadczam się że produkt:

Przeciwpożarowa klapa odcinająca typu PKI-C, klasa EI 60 S

Przeciwpożarowa klapa odcinająca typu PKI-C, klasa EI 120 S

jest definiowana jako przegroda odcinająca w okrągłym kanale wentylacyjnym do montażu pionowego lub poziomego i uniemożliwia przejście ognia przez przegrodę w miejscu montażu kanału wentylacyjnego w przegrodzie. Klapa przeciwpożarowa odcinająca jest automatycznie zamykana aby ograniczyć rozprzestrzenianie się ognia, ciepła i dymu, kiedy temperatura otoczenia osiągnie określoną temperaturę. Produkt,

wprowadzony na rynek przez

**IMOS - Systemair, s.r.o. Kalinkovo 146, 900 43 Kalinkovo,
Slovak Republic**

I produkowany w fabryce

**IMOS - Systemair, s.r.o. Kalinkovo 146, 900 43 Kalinkovo,
Slovak Republic**

został poddany przez Producenta fabrycznej kontroli produkcji a dalsze badania próbek będą pobierane w fabryce zgodnie z ustalonym planem badań oraz że Certyfikowana jednostka FIRES, s.r.o. przeprowadziła wstępne badanie typu właściwości produktu, wstępną kontrolę fabryki i sprawuje ciągły nadzór, ocenę i kontrolę produkcji.

Ten certyfikat poświadczam, że wszystkie przepisy dotyczące atestacji zgodności oraz właściwości opisane w Aneksie ZA do normy:

EN 15650:2010

są zastosowane oraz że wyrób spełnia wszystkie ustalone wymagania.

Niniejszy certyfikat został wydany po raz pierwszy 16 stycznia 2012r. i pozostaje ważny tak długo, jak warunki ustanowione w zharmonizowanej specyfikacji technicznej w nawiązaniu do warunków produkcji w zakładzie lub zakładowa kontrola produkcji nie ulegną znaczącym zmianom.

Batizovice, 16 stycznia 2012r. (-) pieczęć FIRES, s.r.o.
Podpis: inż. Maria Gasperowa Kierownik jednostki certyfikujące produkty



Product Certification Body accredited by
Slovak national accreditation service



NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 <http://www.fires.sk>



EC – CERTIFICATE OF CONFORMITY

1396 – CPD – 0050

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the Construction Products Directive – (CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Cartridge fire damper PKI-C, type EI 60 S
Cartridge fire damper PKI-C, type EI 120 S

is defined as a closure of horizontal or vertical circular air duct preventing passage of fire in the place of duct penetration through the fire separating construction. The fire damper is automatically closed to limit spread of fire, heat and smoke when the ambient temperature reaches defined temperature. Product,

placed on the market by

**IMOS - Systemair, s.r.o. Kalinkovo 146, 900 43 Kalinkovo,
Slovak Republic**

and produced in the factory

**IMOS - Systemair, s.r.o. Kalinkovo 146, 900 43 Kalinkovo,
Slovak Republic**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body - FIRES, s.r.o. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.


This certificate attests that all provisions concerning the attestation of conformity and the performances described in the Annex ZA of the standard

EN 15650: 2010

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on the 16th January 2012 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Batizovce, 16th January 2012



Ing. Mária Gašperová
Ing. Mária Gašperová
Head of Product Certification Body

039251

FIRES 136/C-23/03/2011-E