



UAB "Sentera Baltica"
Vytauto g.219
LT-77170, Šiauliai
Tel: +370 41 421 941
Fax: +370 41 421 941
Įmonės kodas: 301241078
PVM mokėtojo kodas: LT100003609718
Įmonės registro Nr. 110485

ANG Wentylacja, Sp.z.o.o.
ul. Czeszochowska 24
PL - 32-085 Modlnica
VAT code : PL6772197856

DECLARATION OF CONFORMITY

SENTERA BALTICA declares that the following products:

Autotransformers and transformer controllers for voltage controllable single phase electric motors.

Installed in accordance with the installation standards, manufacturer's instructions and professional rules, duly maintained and used for the applications as intended,

Comply with:

Low voltage
Directive 2006/95/EC on low voltage

EN 60335-1:2002
Household and similar electrical appliances — Safety — Part 1: General requirements (IEC 60335-1:2001 (Modified))
Amendment A11:2004 to EN 60335-1:2002
Amendment A1:2004 to EN 60335-1:2002 (IEC 60335-1:2001/A1:2004)
Amendment A12:2006 to EN 60335-1:2002

EN 61558-1:2005
Safety of power transformers, power supplies, reactors and similar products — Part 1: General requirements and tests (IEC 61558-1:2005)

EN 61558-2-13:2000
Safety of power transformers, power supply units and similar devices — Part 2-13: Particular requirements for auto-transformers for general use (IEC 61558-2-13:1999)

EMC:
Directive 2004/108/EC relating to electromagnetic compatibility

Immunity:
EN 61000-6-2:2005
Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments (IEC 61000-6-2:2005)


Radiation:
EN 61000-6-3:2007
Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments (IEC 61000-6-3:2006)

Harmonics:
EN 61000-3-2:2006
Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase) (IEC 61000-3-2:2005)

The products are to be installed and maintained by skilled personnel.
The CE mark is affixed.

Made in Šiauliai, Lithuania, 28/04/2009 on behalf of ANG Wentylacja, Sp.z.o.o.

Gintaras Mitkevičius





UAB "Sentera Baltica"
Vytauto g.219
LT-77170, Šiauliai
Tel: +370 41 421 941
Fax: +370 41 421 941
Įmonės kodas: 301241078
PVM mokėtojo kodas: LT100003609718
Įmonės registras Nr. 110485

ANG Wentylacja, Sp.z.o.o.
ul. Czeszochowska 24
PL - 32-085 Modlnica
VAT code : PL6772197856

DECLARATION OF CONFORMITY

SENTERA BALTICA declares that the following products:

Electronic speed controllers for voltage controllable single phase electric motors,

Installed in accordance with the installation standards, manufacturer's instructions and professional rules, duly maintained and used for the applications as intended,

Comply with:

Low voltage
Directive 2006/95/EC on low voltage

EN 60335-1:2002
Household and similar electrical appliances — Safety — Part 1: General requirements (IEC 60335-1:2001 (Modified))
Amendment A11:2004 to EN 60335-1:2002
Amendment A1:2004 to EN 60335-1:2002 (IEC 60335-1:2001/A1:2004)
Amendment A12:2006 to EN 60335-1:2002

EN 60669-1:1999
Switches for household and similar fixed-electrical installations — Part 1: General requirements (IEC 60669-1:1998 (Modified))
Amendment A1:2002 to EN 60669-1:1999 (IEC 60669-1:1998/A1:1999 (Modified))

EN 60669-2-1:2004
Switches for household and similar fixed electrical installations — Part 2- 1: Particular requirements — Electronic switches (IEC 60669-2-1:2002 (Modified))

EMC:
Directive 2004/108/EC relating to electromagnetic compatibility

Immunity:
EN 61000-6-2:2005
Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments (IEC 61000-6-2:2005)

Radiation:
EN 61000-6-3:2007
Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments (IEC 61000-6-3:2006)

Harmonics:
EN 61000-3-2:2006
Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase) (IEC 61000-3-2:2005)

The products are to be installed and maintained by skilled personnel.
The CE mark is affixed.

Made in Šiauliai, Lithuania, 28/04/2009, on behalf of ANG Wentylacja, Sp.z.o.o.

Gintaras Mitkevičius

